



No.C- 3513/2019

Office of the District Fire Officer
Fire and Rescue Services
Palakkad. Dated : 04.07.2019
Phone No.0491 2505702
E mail : adopkd.frs@kerala.gov.in

District Fire officer
Fire and Rescue Services
Palakkad.

The Principal
Kendriya Vidhyalaya
Kanjikode
Palakkad.

Sir,

Sub : Fire and rescue Services, Palakkad – Inspection of buildings regarding Fire safety.

We have inspected Kendriya Vidhyalaya, Kanjikode, Palakkad on 22.06.2019 and the following report is forwarded for necessary action. It is found that the school have installed sufficient number of fire extinguishers (DCP & Co₂) which are found to be in good working condition. School mockdrills has to be organised once in 6 months.

We have done a training session on fire safety at the school. More training sessions has to be conducted regularly so as to educate the teachers and students in fire protection, building safety and disaster management. Fire extinguishers should be refilled every year. Sufficient numbner of fire exits should always be ensured for the safe exit & evacuation of students in emergencies/Mockdrill occasions. It will be better to install the fixed fire protection system in the building as National Building Code of India 2016 part IV in future.



Yours faithfully

District Fire officer
Fire and Rescue Services
Palakkad